


MAIS DE 30 ANOS  
A CONVERTER  
CONHECIMENTO  
EM VALOR

# Laboratório de Fumo e Fogo

## Reaction to Fire Tests

Test Report No. LFF.2019.133.02

SONAE – INDÚSTRIA DE REVESTIMENTOS, S.A.



The presented results refer exclusively to tested specimens.  
This document may not be reproduced, except in its integrity, without permission in writing by INEGI.

## 0. DOCUMENT CONTROL AND IDENTIFICATION

### 0.1 DOCUMENT IDENTIFICATION

Project	---
Document Name	Test Report No. LFF.2019.133.02
Document File Name	---

### 0.2 VERSION CONTROL

Version	Edition	Revision	Date	Description	Approved by
1	1	0	2019-10-30	Original version	JMG

### 0.3 AUTHOR(S)

Name	Entity	Initials
José Mesquita Guimarães - Technical Director of the Laboratory	INEGI	JMG

### 0.4 REVISER(S)

Name	Entity	Initials
Anabela Martins - Laboratory Technician	INEGI	AM

### 0.5 LABORATORY TECHNICIANS(S)

Name	Entity	Initials
Bruno Nogueira - Laboratory Technician	INEGI	BN

### 0.6 DISTRIBUTION LIST

Name	Entity	Initials
Laboratório de Fumo e Fogo	INEGI	LFF
---	SONAE, S.A.	---

0.7 IDENTIFICATION

**Cliente** Sonae – Indústria de Revestimentos, S.A.

**Address:** Lugar do Espido – Via Norte  
4470-177

**Request:** Tests according to EN 13823:2010 A1 November 2014

**Request Reference:** PE30190597


**Request Date:** 2019-07-05

**Material Reference:** Surforma HPL AC3 (0.8 – 1.2 mm)

**Reception Date:** 2019-07-23

**Test Date:** 2019-07-30 and 2019-07-31

**Report Date:** 2019-10-30



**INDEX**

1. INTRODUCTION ..... 6

2. METHODOLOGY ..... 6

3. SPECIMENS ..... 6

4. RESULTS ..... 7

5. LIMITATIONS ..... 8

## 1. INTRODUCTION

This report refers to exploratory fire reaction tests and the potential classification of materials with the reference “Surforma HPL AC3 (0.8 – 1.2 mm)”.

## 2. METHODOLOGY

Test	Test procedure
Reaction to fire tests for building products. Building products exposed to the thermal attack by a single burning item.	EN 13823:2010 A1 november 2014

## 3. SPECIMENS

### 3.1 Dimension and conditioning

The specimens were prepared by the client, having the following dimensions and masses:

Reference	Length (mm)	Width (mm)	Thickness (mm)	Mass (g)
LFF.2019.133.01	1506	1000	0.8	1732
LFF.2019.133.02	1500	500	0.8	867
LFF.2019.133.03	1504	1000	0.8	1787
LFF.2019.133.04	1503	497	0.8	849

Prior to testing, the specimens were conditioned for a period of 170 hours at  $23 \pm 2$  °C and  $50 \pm 5$  % relative humidity, having met the constant mass criterion.

### 3.2 Mounting of specimens

Specimens were tested free standing according (according to 5.2.2.a of the norm EN 13823).

#### 4. RESULTS

Specimens	LFF.2019.133.01 and LFF.2019.133.02	LFF.2019.133.03 and LFF.2019.133.04
FIGRA <sub>0,2 MJ</sub> (W/s)	1209.5	806.6
FIGRA <sub>0,4 MJ</sub> (W/s)	1209.5	806.6
THR <sub>600 s</sub> (MJ)	5.3	5.1
LFS (m)	No	No
FIRE BEHAVIOUR	E	E
SMOGRA (m <sup>2</sup> /s <sup>2</sup> ) (*)	17.5	19.9
TSP <sub>600s</sub> (m <sup>2</sup> ) (*)	30.6	30.7
SMOKE PRODUCTION	s1	s1
FLAMING DROPLETS/PARTICLES	No	No
FLAMING DROPLETS	d0	d0

FIGRA: Fire growth rate THR: Total heat release LFS: Lateral flame spread (\*): With smoke correction  
SMOGRA: Smoke growth rate TSP: Total smoke production TNR: Threshold not reached

“The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.”

## 5. LIMITATIONS

All the information on this document regarding the product description has been supplied by the sponsor at no responsibility by INEGI's laboratory.


This document does not represent any type of approval or certification of the product.

This classification document is valid for 5 (five) years.


Porto, October 30, 2019



José Mesquita Guimarães  
Laboratory Technical Director







**ANNEX I**

Photographs




Figure 1 – View of mounting.



Figure 2 – SBI test.



Figure 3 – Test pieces at the end of the test.



**ANNEX II**

**SBI Reports**

# SBI Test Report

Laboratory name INEGI - LFF  
 Operator Bruno Nogueira  
 Filename C:\SBICALC\DATA\19070004.RW1  
 Report identification LFF.2019.133  
 Product identification SURFORMA HPL AC 3 (0.8 - 1.2 mm)

Test		Pre-test conditions		Specimen conditioning	
Standard used	EN 13823:2010	Baseline duct temperature	295.22 K	Method	Constant mass
Date of test	30/07/2019	Ambient temperature	294.79 K	Time interval	173 hours
Date of report	30/07/2019	Ambient pressure	100.3 kPa	Mass 1	2598 g
E'	17.2 MJ/m <sup>3</sup>	Relative humidity	50%	Mass 2	2599 g
Apparatus specifications		Baseline conditions		Temperature	23°C
kt	0.823	Baseline ambient oxygen	20.669%	RH	50%
kp	1.08	Baseline oxygen	20.947%		
Duct diameter	0.315 m	Baseline carbon dioxide	0.0806%		
O2 calibration delay time	10 s	Baseline smoke	100.05%		
CO2 calibration delay time	12 s				

Specimen information			
Thickness	0.8 mm	Mounting method	5.2.2a) in EN 13823:2002
Density	1443.8 kg/m <sup>3</sup>	Joints	none
Surface mass/area	1.15 kg/m <sup>2</sup>	Fixed to substrate?	No
Specimen number	1	Fixing method	N/A
Date of arrival	23/07/2019	Substrate	none
		Manufacturer	SONAE INDÚSTRIA DE REVESTIMENTOS, SA
		Sponsor	SONAE INDÚSTRIA DE REVESTIMENTOS, SA

## Test validity criteria

### Test drifts

	Initial	Final	Change
Oxygen	20.947%	20.938%	0.009%
CO2	0.081%	0.093%	0.012%
Smoke	100.05%	99.87%	0.002

Exposure time 1194 s

### Synchronisation details

Duct temp. dropped by 2.5 K from baseline of 320.23 K at 303 s  
 Oxygen rose by 0.05% from baseline of 20.645% at 306 s  
 CO2 dropped by 0.02% from baseline of 0.327% at 303 s

### Burner details

Burner HRR	26.225 kW
Burner HRR std. dev.	0.544 kW
Burner CO2/O2 ratio	0.814
Burner SPR	0.026 m <sup>2</sup> /s
Burner SPR std. dev.	0.004 m <sup>2</sup> /s
Burner response time	12 s

### Other checks

Minimum duct flow	0.424 m <sup>3</sup> /s
Maximum duct flow	0.548 m <sup>3</sup> /s
No T/C failure	

Classification results		Classification observations		Potential classification	
FIGRA(0.2)	1209.5 W/s at 366 s	LFS to edge?	No	Class	E
FIGRA(0.4)	1209.5 W/s at 366 s	FDP flaming <= 10s?	No	Smoke production	s1
THR(600)	5.3 MJ	FDP flaming > 10s?	No	Flaming droplets/particles	d0
SMOGRA	17.5 m <sup>2</sup> /s <sup>2</sup> at 381 s				
TSP(600)	30.6 m <sup>2</sup>				

**Recorded events** Surface flashes? No; Falling specimen parts? Yes; Smoke not entering hood? No  
 Mutual fixing of backing board failed? No; Distortion/collapse of specimen? No


### Pre-test comments

**After-test comments** Aos 335 s, Formação de bolas gasosas na superfície do provete, até cerca de 35 cm do canto, a toda a altura. Sucessivo rebentamento das bolhas formadas. Aos 350 s, destruição de grande parte do provete no canto, até ao topo e até cerca de 25 cm do canto. Aos 475 s, provete totalmente destruído no canto até 75 cm de altura e ceca de 25 cm.


# SBI Test Report

Laboratory name INEGI - LFF  
Operator Bruno Nogueira  
Filename C:\SBICALC\DATA\19070004.RW1  
Report identification LFF.2019.133  
Product identification SURFORMA HPL AC 3 (0.8 - 1.2 mm)

## HRR and HRR(30) graph



## THR and FIGRA graph




The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.


# SBI Test Report

Laboratory name INEGI - LFF  
Operator Bruno Nogueira  
Filename C:\SBICALC\DATA\19070004.RW1  
Report identification LFF.2019.133  
Product identification SURFORMA HPL AC 3 (0.8 - 1.2 mm)

## SPR and SPR(60) graph



## TSP and SMOGRA graph



The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.

# SBI Test Report

Laboratory name INEGI - LFF  
 Operator Bruno Nogueira  
 Filename C:\SBICALC\DATA\19070007.RW1  
 Report identification LFF.2019.133  
 Product identification SURFORMA HPL AC 3 (0.8 - 1.2 mm)

Test		Pre-test conditions		Specimen conditioning	
Standard used	EN 13823:2010	Baseline duct temperature	295.54 K	Method	Constant mass
Date of test	31/07/2019	Ambient temperature	295.05 K	Time interval	198 hours
Date of report	31/07/2019	Ambient pressure	99.98 kPa	Mass 1	2631 g
E'	17.2 MJ/m <sup>3</sup>	Relative humidity	50%	Mass 2	2636 g
Apparatus specifications		Baseline conditions		Temperature	23°C
kt	0.823	Baseline ambient oxygen	20.667%	RH	50%
kp	1.08	Baseline oxygen	20.951%		
Duct diameter	0.315 m	Baseline carbon dioxide	0.0892%		
O2 calibration delay time	10 s	Baseline smoke	100.01%		
CO2 calibration delay time	12 s				

## Specimen information

Thickness	0.8 mm	Mounting method	5.2.2a) in EN 13823:2002
Density	1464.4 kg/m <sup>3</sup>	Joints	none
Surface mass/area	1.17 kg/m <sup>2</sup>	Fixed to substrate?	No
Specimen number	2	Fixing method	N/A
Date of arrival	23/07/2019	Substrate	none
		Manufacturer	SONAE INDÚSTRIA DE REVESTIMENTOS, SA
		Sponsor	SONAE INDÚSTRIA DE REVESTIMENTOS, SA

## Test validity criteria

### Test drifts

	Initial	Final	Change
Oxygen	20.951%	20.922%	0.030%
CO2	0.089%	0.088%	0.001%
Smoke	100.01%	99.89%	0.001

Exposure time 1254 s

### Synchronisation details

Duct temp. dropped by 2.5 K from baseline of 320.42 K at 303 s  
 Oxygen rose by 0.05% from baseline of 20.643% at 306 s  
 CO2 dropped by 0.02% from baseline of 0.331% at 303 s

### Burner details

Burner HRR	26.766 kW
Burner HRR std. dev.	0.556 kW
Burner CO2/O2 ratio	0.783
Burner SPR	0.026 m <sup>2</sup> /s
Burner SPR std. dev.	0.005 m <sup>2</sup> /s
Burner response time	12 s

### Other checks

Minimum duct flow	0.444 m <sup>3</sup> /s
Maximum duct flow	0.552 m <sup>3</sup> /s
No T/C failure	

## Classification results

FIGRA(0.2)	806.6 W/s at 357 s
FIGRA(0.4)	806.6 W/s at 357 s
THR(600)	5.1 MJ
SMOGRA	19.9 m <sup>2</sup> /s <sup>2</sup> at 369 s
TSP(600)	30.7 m <sup>2</sup>

## Classification observations

LFS to edge?	No
FDP flaming <= 10s?	No
FDP flaming > 10s?	No

## Potential classification

Class	E
Smoke production	s1
Flaming droplets/particles	d0

## Recorded events

Surface flashes? No; Falling specimen parts? No; Smoke not entering hood? No  
 Mutual fixing of backing board failed? No; Distortion/collapse of specimen? No

## Pre-test comments

## After-test comments


Aos 350s, formação de bolas gasosas do provete, até cerca de 40cm do canto, a toda a altura. Sucessivo rebentamento das bolhas formadas. Aos 363s, destruição de grande parte do provete no canto, até ao topo. Aos 495s, provete totalmente destruído no canto até 80cm de altura.




# SBI Test Report

Laboratory name INEGI - LFF  
Operator Bruno Nogueira  
Filename C:\SBICALC\DATA\19070007.RW1  
Report identification LFF.2019.133  
Product identification SURFORMA HPL AC 3 (0.8 - 1.2 mm)

## HRR and HRR(30) graph



## THR and FIGRA graph




The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.




# SBI Test Report

Laboratory name INEGI - LFF  
 Operator Bruno Nogueira  
 Filename C:\SBICALC\DATA\19070007.RW1  
 Report identification LFF.2019.133  
 Product identification SURFORMA HPL AC 3 (0.8 - 1.2 mm)

**SPR and SPR(60) graph**



**TSP and SMOGRA graph**



The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.







MAIS DE 30 ANOS  
A CONVERTER  
CONHECIMENTO  
EM VALOR

**INEGI - Instituto de Ciência e Inovação  
em Engenharia Mecânica e Engenharia Industrial**

Campus da FEUP | Rua Dr. Roberto Frias, 400 | 4200-465 Porto | PORTUGAL  
T. +351 22 957 87 10 | F. +351 22 953 73 52 | [inegi@inegi.up.pt](mailto:inegi@inegi.up.pt)

[www.inegi.up.pt](http://www.inegi.up.pt)

