


MAIS DE 30 ANOS
A CONVERTER
CONHECIMENTO
EM VALOR

Laboratório de Fumo e Fogo

Reaction to Fire Tests

Test Report No. LFF.2019.135.02

SONAE – INDÚSTRIA DE REVESTIMENTOS, S.A.



The presented results refer exclusively to tested specimens.
This document may not be reproduced, except in its integrity, without permission in writing by INEGI.

0. DOCUMENT CONTROL AND IDENTIFICATION

0.1 DOCUMENT IDENTIFICATION

Project	---
Document Name	Test Report No. LFF.2019.135.02
Document File Name	---

0.2 VERSION CONTROL

Version	Edition	Revision	Date	Description	Approved by
1	1	0	2019-10-31	Original version	JMG

0.3 AUTHOR(S)

Name	Entity	Initials
José Mesquita Guimarães - Technical Director of the Laboratory	INEGI	JMG

0.4 REVISER(S)

Name	Entity	Initials
Anabela Martins - Laboratory Technician	INEGI	AM

0.5 LABORATORY TECHNICIANS(S)

Name	Entity	Initials
Bruno Nogueira - Laboratory Technician	INEGI	BN

0.6 DISTRIBUTION LIST

Name	Entity	Initials
Laboratório de Fumo e Fogo	INEGI	LFF
---	SONAE, S.A.	---

0.7 IDENTIFICATION

Cliente Sonae – Indústria de Revestimentos, S.A.

Address: Lugar do Espido – Via Norte
4470-177

Request: Tests according to EN 13823:2010 A1 November 2014

Request Reference: PE30190597


Request Date: 2019-07-05

Material Reference: Surforma HPL AC5 (0.8 – 1.2mm)

Reception Date: 2019-07-23

Test Date: 2019-07-31; 2019-08-01

Report Date: 2019-10-31



INDEX

1. INTRODUCTION	6
2. METHODOLOGY	6
3. SPECIMENS	6
4. RESULTS	7
5. LIMITATIONS	8

1. INTRODUCTION

This report refers to exploratory fire reaction tests and the potential classification of materials with the reference “Surforma HPL AC5 (0.8 – 1.2mm)”.

2. METHODOLOGY

Test	Test procedure
Reaction to fire tests for building products. Building products exposed to the thermal attack by a single burning item.	EN 13823:2010 A1 november 2014

3. SPECIMENS

3.1 Dimension and conditioning

The specimens were prepared by the client, having the following dimensions and masses:

Reference	Length (mm)	Width (mm)	Thickness (mm)	Mass (g)
LFF.2019.135.01	1499	1001	0.8	1721
LFF.2019.135.02	1502	497	0.8	887
LFF.2019.135.03	1501	1001	0.8	1812
LFF.2019.135.04	1502	500	0.8	882

Prior to testing, the specimens were conditioned for a period of 170 hours at 23 ± 2 °C and 50 ± 5 % relative humidity, having met the constant mass criterion.

3.2 Mounting of specimens

Specimens were tested free standing according (according to 5.2.2.a of the norm EN 13823).

4. RESULTS

Specimens	LFF.2019.135.01 and LFF.2019.135.02	LFF.2019.135.03 and LFF.2019.135.04
FIGRA _{0,2 MJ} (W/s)	1152.3	1769.7
FIGRA _{0,4 MJ} (W/s)	1152.3	1769.7
THR _{600 s} (MJ)	8.0	9.9
LFS (m)	No	No
FIRE BEHAVIOUR	E	E
SMOGRA (m ² /s ²) (*)	22.8	26.7
TSP _{600s} (m ²) (*)	43.8	22.3
SMOKE PRODUCTION	s1	s1
FLAMING DROPLETS/PARTICLES	No	No
FLAMING DROPLETS	d0	d0

FIGRA: Fire growth rate THR: Total heat release LFS: Lateral flame spread (*): With smoke correction
SMOGRA: Smoke growth rate TSP: Total smoke production TNR: Threshold not reached

“The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.”

5. LIMITATIONS

All the information on this document regarding the product description has been supplied by the sponsor at no responsibility by INEGI's laboratory.


This document does not represent any type of approval or certification of the product.


This classification document is valid for 5 (five) years.

Porto, October 31, 2019



José Mesquita Guimarães
Laboratory Technical Director





ANNEX I

Photographs




Figure 1 – View of mounting.



Figure 2 – SBI test.



Figure 3 – Test pieces at the end of the test.



ANNEX II

SBI Reports

SBI Test Report

Laboratory name INEGI - LFF
 Operator Bruno Nogueira
 Filename C:\SBICALC\DATA\19070008.RW1
 Report identification LFF.2019.135
 Product identification SURFORMA HPL AC 5 (0.8 - 1.2 mm)

Test		Pre-test conditions		Specimen conditioning	
Standard used	EN 13823:2010	Baseline duct temperature	295.23 K	Method	Constant mass
Date of test	31/07/2019	Ambient temperature	294.07 K	Time interval	202 hours
Date of report	31/07/2019	Ambient pressure	99.81 kPa	Mass 1	2603 g
E'	17.2 MJ/m ³	Relative humidity	49%	Mass 2	2608 g
Apparatus specifications		Baseline conditions		Temperature	23°C
kt	0.823	Baseline ambient oxygen	20.676%	RH	50%
kp	1.08	Baseline oxygen	20.950%		
Duct diameter	0.315 m	Baseline carbon dioxide	0.0801%		
O2 calibration delay time	10 s	Baseline smoke	100.08%		
CO2 calibration delay time	12 s				

Specimen information

Thickness	0.8 mm	Mounting method	5.2.2a) in EN 13823:2002
Density	1448.8 kg/m ³	Joints	none
Surface mass/area	1.15 kg/m ²	Fixed to substrate?	No
Specimen number		Fixing method	N/A
Date of arrival	23/07/2019	Substrate	none
		Manufacturer	SONAE INDÚSTRIA DE REVESTIMENTOS, SA
		Sponsor	SONAE INDÚSTRIA DE REVESTIMENTOS, SA

Test validity criteria

Test drifts

	Initial	Final	Change
Oxygen	20.950%	20.943%	0.007%
CO2	0.080%	0.083%	0.003%
Smoke	100.08%	100.15%	0.001

Exposure time 894 s

Synchronisation details

Duct temp. dropped by 2.5 K from baseline of 320.40 K at 303 s
 Oxygen rose by 0.05% from baseline of 20.645% at 303 s
 CO2 dropped by 0.02% from baseline of 0.329% at 303 s

Burner details

Burner HRR	26.546 kW
Burner HRR std. dev.	0.583 kW
Burner CO2/O2 ratio	0.815
Burner SPR	0.023 m ² /s
Burner SPR std. dev.	0.006 m ² /s
Burner response time	9 s

Other checks

Minimum duct flow	0.416 m ³ /s
Maximum duct flow	0.544 m ³ /s
No T/C failure	

Classification results

FIGRA(0.2)	1152.3 W/s at 375 s
FIGRA(0.4)	1152.3 W/s at 375 s
THR(600)	8.0 MJ
SMOGRA	22.8 m ² /s ² at 384 s
TSP(600)	43.8 m ²

Classification observations

LFS to edge?	No
FDP flaming <= 10s?	No
FDP flaming > 10s?	No

Potential classification

Class	E
Smoke production	s1
Flaming droplets/particles	d0

Recorded events

Surface flashes? No; Falling specimen parts? Yes; Smoke not entering hood? No
 Mutual fixing of backing board failed? No; Distortion/collapse of specimen? No

Pre-test comments


After-test comments

Aos 330 s, Formação de bolhas gasosas na superfície do provete, até cerca de 30 cm do canto, a toda a altura do provete. Sucessivo rebentamento das bolhas. Aos 370 s, Destruição do provete no canto, a toda a altura e até 25 cm na horizontal. Algumas partículas incandescentes flutuam, extinguindo-se em alguns segundos, antes de atingirem a base.


SBI Test Report

Laboratory name INEGI - LFF
Operator Bruno Nogueira
Filename C:\SBICALC\DATA\19070008.RW1
Report identification LFF.2019.135
Product identification SURFORMA HPL AC 5 (0.8 - 1.2 mm)

HRR and HRR(30) graph



THR and FIGRA graph




The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.


SBI Test Report

Laboratory name INEGI - LFF
 Operator Bruno Nogueira
 Filename C:\SBICALC\DATA\19070008.RW1
 Report identification LFF.2019.135
 Product identification SURFORMA HPL AC 5 (0.8 - 1.2 mm)

SPR and SPR(60) graph



TSP and SMOGRA graph



The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.

SBI Test Report

Laboratory name INEGI - LFF
 Operator Bruno Nogueira
 Filename C:\SBICALC\DATA\19080001.RW1
 Report identification LFF.2019.135
 Product identification SURFORMA HPL AC 5 (0.8 - 1.2 mm)

Test		Pre-test conditions		Specimen conditioning	
Standard used	EN 13823:2010	Baseline duct temperature	295.02 K	Method	Constant mass
Date of test	01/08/2019	Ambient temperature	295.25 K	Time interval	202 hours
Date of report	01/08/2019	Ambient pressure	99.84 kPa	Mass 1	2694 g
E'	17.2 MJ/m ³	Relative humidity	51%	Mass 2	2691 g
Apparatus specifications		Baseline conditions		Temperature	23°C
kt	0.823	Baseline ambient oxygen	20.660%	RH	50%
kp	1.08	Baseline oxygen	20.942%		
Duct diameter	0.315 m	Baseline carbon dioxide	0.0819%		
O2 calibration delay time	10 s	Baseline smoke	100.02%		
CO2 calibration delay time	12 s				

Specimen information

Thickness	0.8 mm	Mounting method	5.2.2a) in EN 13823:2002
Density	1495 kg/m ³	Joints	none
Surface mass/area	1.19 kg/m ²	Fixed to substrate?	No
Specimen number	2	Fixing method	N/A
Date of arrival	23/07/2019	Substrate	none
		Manufacturer	SONAE INDÚSTRIA DE REVESTIMENTOS, SA
		Sponsor	SONAE INDÚSTRIA DE REVESTIMENTOS, SA

Test validity criteria

Test drifts

	Initial	Final	Change
Oxygen	20.942%	20.868%	0.074%
CO2	0.082%	0.082%	0.000%
Smoke	100.02%	100.32%	0.003

Exposure time 1254 s

Synchronisation details

Duct temp. dropped by 2.5 K from baseline of 320.06 K at 303 s
 Oxygen rose by 0.05% from baseline of 20.622% at 306 s
 CO2 dropped by 0.02% from baseline of 0.331% at 303 s

Burner details

Burner HRR	28.461 kW
Burner HRR std. dev.	0.989 kW
Burner CO2/O2 ratio	0.781
Burner SPR	0.025 m ² /s
Burner SPR std. dev.	0.005 m ² /s
Burner response time	3 s

Other checks

Minimum duct flow	0.394 m ³ /s
Maximum duct flow	0.545 m ³ /s
No T/C failure	

Classification results

FIGRA(0.2)	1769.7 W/s at 363 s
FIGRA(0.4)	1769.7 W/s at 363 s
THR(600)	9.9 MJ
SMOGRA	26.7 m ² /s ² at 366 s
TSP(600)	22.3 m ²

Classification observations

LFS to edge?	No
FDP flaming <= 10s?	No
FDP flaming > 10s?	No

Potential classification

Class	E
Smoke production	s1
Flaming droplets/particles	d0

Recorded events

Surface flashes? No; Falling specimen parts? Yes; Smoke not entering hood? No
 Mutual fixing of backing board failed? No; Distortion/collapse of specimen? No

Pre-test comments

After-test comments


Aos 325 s, formação de bolhas gasosas na superfície do provete, até cerca de 30cm do canto, a toda a altura do provete. Sucessivo rebentamento de bolhas. Aos 365 s, destruição do provete no canto, a toda a altura e até 30cm na horizontal. Partículas incandescentes flutuam, extinguindo-se antes de atingirem a base.




SBI Test Report

Laboratory name INEGI - LFF
Operator Bruno Nogueira
Filename C:\SBICALC\DATA\19080001.RW1
Report identification LFF.2019.135
Product identification SURFORMA HPL AC 5 (0.8 - 1.2 mm)

HRR and HRR(30) graph



THR and FIGRA graph




The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.




SBI Test Report

Laboratory name INEGI - LFF
 Operator Bruno Nogueira
 Filename C:\SBICALC\DATA\19080001.RW1
 Report identification LFF.2019.135
 Product identification SURFORMA HPL AC 5 (0.8 - 1.2 mm)

SPR and SPR(60) graph



TSP and SMOGRA graph



The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.





**MAIS DE 30 ANOS
A CONVERTER
CONHECIMENTO
EM VALOR**

**INEGI - Instituto de Ciência e Inovação
em Engenharia Mecânica e Engenharia Industrial**

Campus da FEUP | Rua Dr. Roberto Frias, 400 | 4200-465 Porto | PORTUGAL
T. +351 22 957 87 10 | F. +351 22 953 73 52 | inegi@inegi.up.pt

www.inegi.up.pt

